

SAFETY AND BUILDINGS DIVISION Plumbing Product Review P.O. Box 2658 Madison, Wisconsin 53701-2658

Jim Doyle, Governor Jack L. Fischer, A.I.A., Secretary

June 4, 2008

KITCHENS TO GO,LLC FRED STOWELL 131 W JEFFERSON AVE NAPERVILLE IL 60540 CARLIN MANUFACTURING, LLC SCOTT KAROLL 131 W JEFFERSON AVE NAPERVILLE IL 60540

Re: Description: PREFABRICATED PLUMBING SYSTEM

Manufacturer: CARLIN MANUFACTURING, LLC

Product Name: MOBILE KITCHEN

Model Number(s): M577 Product File No: 20080238

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2013.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 46 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means
 concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in
 a modular building component, which will not be visible for inspection when delivered to the final site of
 installation.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson Plumbing Product Reviewer Phone: 608-266-6742 Fax: 608-267-9566

E-mail: Jerry.Thompson@wi.gov

SBD-10564-E (N.10/97) File Ref: 08023805.DOC